

ABSTRACT

Several industries utilize sequential industrial process which is respective in nature. For such processes industries have to depend upon use of relays, stepping drum, timers and controls considerable difficulties experienced in reprogramming necessitated due to change in the nature of production. Often the whole system has to be scrapped and a redesigning is required. To overcome these problems PLC control system was introduced. The PLC can be described as a control ladder comprising a sequence program. PLC sequence program consists of normally open and normally closed contacts connected in parallel or in series. It also has relay coils, which turns ON and OFF as the state of these contacts change. In this paper, about all aspects of these powerful and versatile tools and its applications to process automation has been discussed.

Keywords: Automation, Programmable Logic Controller (PLC), Programming Languages, Process Automation.

I. INTRODUCTION

With the upcoming technologies and availability of motion control of electric drives, the application of Programmable Logic Controllers with power electronics in electrical machines has been introduced in the development of automation systems. The use of PLC in automation processes increases reliability, flexibility and reduction in production cost. Use of PLC interfaced with power converters, personal computers and other electric equipment makes industrial electric drive systems more accurate and efficient [1];

PARLE is the market leader in the organized biscuit and candy market in India. Biscuit contribute to more than 80% of parle's total turnover. Other products include cookies and candies.

The biscuit market is estimated to be 11mn TPA, valued at rupees 35bn. The unorganized sector accounts for 50% of market. The market has been growing at a CAGR of 6-7% per capita consumption of biscuit is estimated at a low 15kgs, reflecting the huge potential for growth. In the organized sector, Parle and Britannia are the only national players with dominant market shares. PLCs have been gaining popularity on the factory floor and will probably remain preponderant in coming years. Most of this is because of the advantages they offer, like

- Cost effective for controlling complex systems.
- Flexible and can be reapplied to control other systems quickly and easily.
- Computational abilities allow more sophisticated control.
- Trouble shooting makes programming easier and reduce downtime.
- Reliable components make these likely to operate for years before failure.

The PLC was contrived in response to the needs of the American automotive manufacturing industry. Automotive industries were the first to adopt programmable logic controllers, where software alteration replaced the rewiring of hard-wired control panels when production models changed. In manufacturing automobiles earlier, the control, sequencing and the safety interlock logic was accomplished using hundreds or thousands of relays, drum sequencers, cam timers, and closed-loop controllers. The process for updating such facilities for the yearly model change-over was very expensive and time-consuming as electricians have to individually rewire each and every relay. Digital computers, being general-purpose programmable devices, were applied for the control of industrial processes. Early computers required specialist programmers and essential operating environmental control for temperature, cleanliness, and power quality. The general-purpose computer used for process control required protecting the computer

[ICEMESM-18]

ICTM Value: 3.00

from the plant floor conditions. An industrial control computer possess several attributes: it would tolerate the shop-floor environment, it would not require years of training to use, and it would permit its operation to be monitored, it would support discrete (bit-form) input and output in an easily extensible manner. The response time of any computer system must be fast enough to be useful for control; the required speed varying according to the nature of the process [2].

In 1968, the design criteria for the first programmable controllers were specified by the Hydromatic Division of the General Motors Corporation. Eliminating the high costs associated with inflexible, relay-controlled systems was their primary goal. The specifications required a solid-state system with computer flexibility able to (a) Survive in an industrial environment, (b) Be easily programmed and maintained by plant engineers and technicians, (c) Be reusable. Such control system would reduce machine downtime and provide expandability for the future. The automotive industry is still one of the largest users of PLCs [13].

II. RESEARCH OBJECTIVES

The important objectives study was:

- A. increases the manufacturing capacity in the small scale food industry
- B. increases the labor integrity in the productivity of food
- C. Eliminate the human based operations, reduces the cost and time of the product.

This project proposes an idea about automation of Food Processing plant using the PLC. In this plant biscuits are prepared with the help of raw materials. The objective of this project is to convert the manual project into fully automated plant for achieving higher accuracy & high hygiene, and to save time and raw material. Automated plant also helps to increase the quality of product. The system uses intelligent equipment's on site which deliver physical parameters (Analog/Digital) to PLC for easy monitoring of plant. Automation is not a newer concept. Automation is the use of machines, control systems and information technologies to optimize productivity in the production of goods and delivery of services. A Programmable Logic Controller, PLC is a digital computer used for automation of electromechanical processes, such as control of machinery on factory assembly lines, amusement rides, or light fixtures. Simplification of engineering and precise control of manufacturing process can result in significant cost savings.

PROGRAMMABLE LOGIC CONTROLLERS

Nowadays food processing industries are coming up with good quality of products due to automated plants which are well equipped with PLC's (Programmable Logic Controllers) at every stage. Basically PLC (Programmable Logic Controller) is a device more precisely a system- which can control logical or sequential operation of event/s/device along with the associated interlocking conditions applicable for start/stop of that device. Parle Biscuits Ltd. Bahadurgarh, is one of the leading concerns in biscuit manufacturing. In late seventies with fully mechanical set up where large manpower was required. High power consumption was in demand by plant. Then in mid-eighties they converted the plant into semi-automated plant by replacing mechanical panels with electronics panels but they too were bulky. In mid-nineties, they have emerged with fully automated plant by replacing bulky electronics panel with sophisticated and lightweight PLC panels at every stage of plant right from auto weighting of Maida & sugar to packaging of biscuits in packets and putting packets into boxes. Many companies are active in manufacturing PLC's At Parle Biscuits Ltd.

The programming technique for the first PLCs were based on relay logic wiring schematics. This eliminated the need to teach the technicians, electricians and engineers how to program a computer but this method has stuck and it is the most common technique for programming PLCs today. According to IEC 61131-3 five programming languages is defined for programmable control systems: LD (Ladder diagram), ST (Structured text), SFC (Sequential function chart), FBD (Function block diagram), and IL (Instruction list, similar to assembly language) [13,14].

III. INDUSTRIAL AUTOMATION SYSTEMS

Industrial automation is the use of computer and machinery aided systems to operate the various industrial operations in well controlled manner. Based on the operations involved, the industrial automation systems are majorly divided into two types; (a) Manufacturing automation and (b) Process plant automation systems.

IV. BASIC ARCHITECTURE OF A PLC




Figure 0.1 circuit diagram of PLC

APLC system comprises of :

- INPUTS
- OUTPUTS
- CENTRAL PROCESSING UNIT
- MEMORY FOR PROGRAM AND DATA STORAGE
- POWER SUPPLY
- PROGRAMMING DEVICES
- OPERATOR INTERFACES

All PLC's from micro to very large, use these same basic components and are structured in the similar fashion as shown below.

Inputs:

The input screw terminals on a PLC form the interface which field connects devices to the PLC. Inputs include items such as pushbuttons, thumbwheel switches, limit switches, selector switches, proximity sensors and photoelectric sensors. These are all discrete devices that provide an on or off status to the PLC. The electrical signals that field devices send to the PLC are typically unfiltered 120V ac or 24V dc

Outputs:

The outputs connected to the output terminals of the PLC are devices like solenoids, relays, contractor, motor starters, indicator lights, valves and alarms. Output circuits operate in a manner similar to input circuits: signals from the CPU pass through an isolation barrier before energizing output circuits.

Central processing unit (cpu):

The CPU made up of a microprocessor and a memory system forms the primary component of the PLC. The CPU reads the inputs, executes logics as dictated by the application program, performs the calculations and controls the output accordingly. PLC works with two areas of the CPU, program files and data files.

Program files store a user's application program, subroutine files and error files.

Data files store data associated with the program such as I/O Status, timer counters, preset and accumulated values and other stored constants or variables. Together these two areas are called the application or user memory.

Types of memory:

Programmable Logic Controllers have programmable memory that allows users to develop and modify the control programs. Memory is a physical space inside the CPU where the program and data files are stored and manipulated.

Memory types fall in two categories:

Volatile memory can be easily altered or erased and it can be

Written to and written from however without proper backup, a power loss can cause a loss of programmed contents.

Non-Volatile memory retains its programmed contents without battery or capacitor backups even if power is lost.

Operating cycle :

All the components of the PLC system come into play during the operating cycle, which consists of operations performed sequentially and repeatedly. The major elements of an operating cycle are:

the input scan: During the input scan, the PLC examines the external input device for a voltage present or absent that is ON/OFF state. The status of the inputs is temporarily stored in an "input image" memory file.

program scan: During the program scan, the PLC scans the instructions in the ladder logic program, uses the input status from the input image file and determines if an output will or will not be energized. The resulting status of the output is written in the "output image" memory file.

output scan: Based on the data in the output image file, the PLC energizes or de-energizes the output circuits, controlling external devices.

Power supplies:

The Power Supply provides power to the controller's internal electronics, converts the incoming voltage to a usable form and protects the PLC components from voltage spikes. A PLC can operate for several milliseconds without the power before the power supply signals can no longer provide adequate dc power to the system. Until recently, all micro PLCs operate on 24 V dc. However several micro PLC manufacturers now offer products that operate either on 120 V ac, 220 V ac or 24V dc.

V. FUTURE SCOPE

The project is designed in such a way that it is a simple and reliable can be used by local industries. However with little modification, it can be used more efficiently and effectively, some of the modifications suggested are

- Less operating time.
- High flexibility
- Absence of moving parts increases reliability
- Low power consumption
- Easy maintenance due to modular fabrication.
- Easy fault finding and diagnostic.
- Capable of handling of complicated logic
- Operations.
- Good documentation and data collecting Facilities
- Easy to interface with the process computers.
- Analog signal handling and close loop control programming.
- Timer, counter and comparator can be programmed.

VI. REFERENCES

- [1] Rinchen G. Dorjee, "PLC and Fuzzy Logic Control of a Variable Frequency Drive," *International journal of engineering trends and technology*, Vol. 16, No. 4, Oct 2014, 2231-5381.
- [2] Sadegh vosough, Amir vosough, "PLC and its Applications," *International journal of Multidisciplinary sciences and engineering*, Vol. 2, No. 8, Nov. 2011, 2045- 7057.
- [3] S. Das, S. Dutta, A. Sarkar, S. Kar, "Recognition and Disposal of Faulty Bottles in a Bottle Filling Industry Using PLC and Producing Human Machine Interface by SCADA", *International Refereed Journal of Engineering and Science (I RJE S)*, pp. 18- 23, ISSN 2319- 183X, Volume 3, Issue 5, May 2014.
- [4] Deepak Kumar Agrawal, "Application Of SCADA System in Steel Industries", Department of Mechanical Engineering, Takshshila Institute of Engineering & Technology, Jabalpur (M.P.), RGPV University Jabalpur (M.P.), Volume 5, Issue 6, June 2015.
- [5] Jing Dai, "The Design of Automatic Temperature Control System for the Dyeing Machine", *Modern applied science*, pp. 72- 79, Vol. 2, No. 5, Sept. 2008.
- [6] K. GOWRI SHANKAR, "control of boiler operation using PLC SCADA" proceeding of the international multi conference engineers and computer scientist 2008.
- [7] ENGINE OZDEMIR, MELUT KARACOR, "mobile phone based SCADA for industrial automation". *ISA transactions* volume 45, number1, Jan 2006.
- [8] V. Bhaskar, T. Gowri Manohar "GSM Based Motor Monitoring and Speed Control". *International journal of mechanical and Industrial Engineering (IJMIE)*, ISSN No. 2231, 6477, Volume1, Issue2, 2011
- [9] Action Nechibvute, Courage Mudgingwa, "Wireless Sensor Networks for SCADA and Industrial Control Systems", Department of Applied Physics and Telecommunication, Midlands State University, Private bag 9055 Gweru, Zimbabwe, Volume 3 No. 12, December, 2013.